



## PPG LABORATORY TEST RESULTS CERTIFICATION

### IMPACT RESISTANCE

PPG Industries, Inc. certifies the following performance properties for the Duranar® Coil Coating System when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

<b>COATING:</b>	DURANAR XL PLUS
<b>TEST:</b>	ASTM D2794-93 - Resistance of Organic Coatings to the Effects of Rapid Deformation (Impact)
<b>SPECIFICATION:</b>	Factory painted sheet will withstand direct and reverse impact in accordance with ASTM D2794 equal to 3.0 X HDG metal thickness or 1.5 X aluminum metal thickness in mils, expressed in inch pounds.
<b>RESULTS:</b>	No loss of adhesion when tested using Scotch brand 610 cellophane tape.

June 3, 2008